

Bacterial Filtration Efficiency (BFE) and Differential Pressure (Delta P) Final Report

Test Article: FMPV2020L
SAMPLE #B1
SAMPLE #B2
SAMPLE #B3
SAMPLE #B4
SAMPLE #B5

Purchase Order: NGPO_O182020
Study number: 1274106-S01
Study received date: 05 March 2020
Testing facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A

Test procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18
Deviation(s): None

Summary: The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.7 - 3.0 \times 10^3$ colony forming units (CFU) with a mean particle size (MPS) of $3.0 \pm 0.3 \mu\text{m}$. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-19 and EN 14683:2019, Annex B.

The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test complies with EN 14683:2019, Annex C and ASTM F2100-19.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test side: Sponsor labeled side
BFE Test area: -40cm²
BFE Flow rate: 28,3 liters per minute (L/min)
Delta P flow rate: 8 liters per minute (L/min)
Conditioning parameters: 85±5% relative humidity (RH) and 21±5°C for a minimum of 4 hours
Positive control average: $1,8 \times 10^3$ CFU
Negative monitor count: < 1 CFU
MPS: 3.0µm

Study Director



James W. Luskin



21 Mar 2020
Study Completion Date



Results:

Test Article Number	Percent BFE (%)
1	99.8
2	99.9
3	99.9
4	99.9
5	>99.9

Test Article	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm ²)
1	4,9	48,2
2	4,9	48,3
3	6,0	58,6
4	5,0	48,6
5	5,6	55,2

The filtration efficiency percentages were calculated using the following equation:

$$\% BFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

Viral Filtration Efficiency (VFE) Final Report

Test Article: FMPV2020L
SAMPLE NO:V1
SAMPLE NO:V2
SAMPLE NO:V3
SAMPLE NO:V4
SAMPLE NO:V5


Purchase Order: NGPO_O182020
Study number: 1274106-S01
Study received date: 05 March 2020
Testing facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A

Test procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18
Deviation(s): None


Summary: The VFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of bacteriophage OX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.1 - 3.3 \times 10^3$ colony forming units (CFU) with a mean particle size (MPS) of $3.0 \pm 0.3 \mu\text{m}$. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test side: Sponsor labeled side
Test area: -40cm 2
VFE Flow rate: 28,3 liters per minute (L/min)
Conditioning parameters: 85±5% relative humidity (RH) and 21±5C for a minimum of 4 hours
Positive control average: $1,9 \times 10^3$ PFU
Negative monitor count: < 1 PFU
MPS: 3.2 μm



Study Director



James W. Luskin





Study Completion Date

Results:

Test Article Number	Percent BFE (%)
V1	99.8
V2	>99.9*
V3	99.9
V4	99.7
V5	99.8

*There were no detected plaques on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request